



- NOTES:**
1. WYES, BENDS, CAPS AND OTHER FITTINGS, AS WELL AS PRESSURE SEWER LATERAL PIPING, SHALL BE POSITIVELY RESTRAINED TO WITHSTAND 150 P.S.I. PRESSURE.
 2. ALL PIPING, FITTINGS, VALVES AND OTHER COMPONENTS SHALL BE CONSIDERED NEW UNLESS NOTED OTHERWISE.

DRAWING NOT TO SCALE

THIS PRINT IS AND CONTAINS PROPRIETARY INFORMATION OWNED EXCLUSIVELY BY CRANE PUMPS & SYSTEMS, INC. THIS RESTRICTION INCLUDES, BUT IS NOT LIMITED TO THE CONDITION THAT THIS PRINT WILL ONLY BE USED AS A RECORD OR TO IDENTIFY OR INSPECT PARTS OR FOR OTHER INFORMATION PURPOSES, AND WILL NOT BE USED TO MANUFACTURE OR PROCURE THE MANUFACTURE OF THE PARTS SHOWN IN THIS PRINT BY ANY OTHER SOURCE THAN CRANE PUMPS & SYSTEMS, INC.

THIS DRAWING IS APPROVED FOR UNCONTROLLED DISTRIBUTION

TITLE

NEW PRESSURE SEWER BRANCH CONNECTION
TO EXISTING FORCE MAIN OR LOW PRESSURE SEWER

CAGE NO

96046

AS A RESULT OF BARNES CONSTANT PRODUCT IMPROVEMENT PROGRAM, PRODUCT CHANGES MAY OCCUR. AS SUCH, BARNES RESERVES THE RIGHT TO CHANGE PRODUCT WITHOUT PRIOR WRITTEN NOTIFICATION

DWG NO

CD141829

REV

A

CRANE

PUMPS & SYSTEMS

BARNES

WWW.BARNESPUMPS.COM

SHEET 1 OF 1